

SEK Sieve Analysis

Sample Type: Tan Jointing Sand (ASTM C-144)

Sample Date: 1/3/14

SIEVE SIZES (% PASSING)

	#4	#8	#16	#30	#50	#100	#200	Pan
ASTM Low	100%	95%	70%	40%	10%	2%	0%	0%
SEK	100%	100%	88%	73%	33%	14%	4%	1%
ASTM High	100%	100%	100%	75%	35%	15%	5%	2%

